

May 2025 Superintendent's Report

Wastewater Treatment Plant:

- Operators performed routine repair and maintenance to the WWTP in May of 2025.
- Sunny weather means operators are again engaged in outdoor painting projects.
- DXP removed the damaged effluent pump April 21 and took it to their shop in Richmond for evaluation. It was more corroded than expected and needs about \$28,000 in repairs, and \$5,000 for installation. Current thinking is to just buy new pumps as planned in the Recycled Water Project
- Operators replaced some old plant potable water lines.
- Operators made some electrical repairs to exterior lighting.
- Operators serviced and replaced several parts on the plant air compressor.
- The Superintendent completed and submitted the Q-1 self-monitoring report last month and we had no violations to report for the period.
- The monthly CASGEM report was also submitted for both April and May of 2025.

Outfall: Alpha Diving has submitted a quote to replace a clamp at joint #8 this summer. Superintendent recommends approval of this quote, to move forward with the repair.

Recycled Water:

-MCCSD did not transfer any recycled water during the month of May 2025. Staff continue working to provide GHD with information as requested.

Biosolids:

-MCCSD operators transported one load of biosolids to Novato in May of 2025.

Grants and Project:

-The GHD SAFER group met Monday 5/19. West Company and GHD are working on draft amendments to the State approved work plan.

-No updates on the Recycled Water Upgrade and Expansion Project.

-MUSD, GHD and Wahlund Construction are moving ahead with the potable water storage tank project. MCCSD has received a handful of letters from property owners requesting to be notified before MUSD conducts pump testing of wells. MUSD staff and consultants are aware of the request.

Safety Meeting and Plant Safety Inspection:

The 30-minute monthly safety meeting was held on May 20, 2025. The topic was *Emergency Evacuation, Getting out Alive*. No safety incidents were reported for the period.

Sanitary Sewer Collection System:

The damaged manhole cover on the corner of Covelo St. and Williams St. has been repaired/replaced. Staff are working to collect estimates for CCTV inspection work and comparing them with the costs of purchasing a new inspection camera. There are no Sanitary Sewer overflows to report for the period April 12, 2023- May 22, 2025.