

October 2025 Superintendent's Report

Wastewater Treatment Plant:

- Operators performed routine repair and maintenance to the WWTP in October of 2025.
 - There were three alarm call outs for the month, all power surge related.
 - RF MacDonald has ordered the replacement filter valves and plans to install them soon.
 - The bar screen continues to have problems. New electrical components were installed, and it now seems to fault about every 3-5 days as opposed to daily. Members of the plant operations committee seemed supportive of purchasing a new unit.
- The third quarter self-monitoring report was turned into the State 10/22. We had no violations for the period.
- The CASGEM groundwater report was turned in 10/21 to the County.
- Operators took a diffuser to the welding shop to install a clean out.

Outfall:

- GHD continues to investigate the idea of slip lining the outfall as longer term repair rather than replacing the unit. Potentially saving \$10 million.

Recycled Water:

- MCCSD did not transfer any recycled water for the month.

Biosolids:

- The biosolids transport trailer received some maintenance, including checking the electrical and breaking systems, replacing a tire, packing the bearings, lubricating joints and suspension, and minor welding work on a fender. It is ready for safe winter transport. Operators plan to transport one load of biosolids to Novato the last week in October.

Grants and Projects:

- FEMA has closed-out our reimbursement request from the 2023 winter storm disaster. It has been transferred to CalOES, with closeout paperwork filed 10/8/25. Hopefully we will receive payment within 90 days.
- The most recent SAFER group meetings were cancelled again this month. We understand GHD has submitted an amended work plan of studies for the State that is under review.
- GHD continues efforts on planning and design of Recycled Water Upgrade and Expansion Project. Surveyors were on site 10/21-10/22.
- MUSD, GHD and Wahlund Construction continue moving ahead with the potable water storage tank project.

Safety Meeting and Plant Safety Inspection:

The 30-minute monthly safety meeting was held on October 23, 2025. The topic was *Emergency Overflow Response*. No safety incidents were reported for the period.

Sanitary Sewer Collection System:

There are no Sanitary Sewer overflows to report for the period April 12, 2023- October 23, 2025. MCCSD conducted some regular maintenance to the Heeser Drive Lift Station.