

June 2026 Superintendent's Report

Wastewater Treatment Plant:

- Operators performed routine repair and maintenance to the WWTP in June of 2026.
- Operators installed a new pressure transducer on the influent wet well on 6/2/26.
- Operators replaced some rotten siding on the pump shed to prepare for painting.
- Operators have been working to digitize and update the plant maintenance log.
- Operators completed a deep clean of the blower room.
- Operators repainted the influent pump gallery pipes and valves.
- DXP is nearly finished with the disassembly and inspection of effluent pump #2
- Staff have resumed reaching out to solar companies to gather information on what might be possible.
- RF MacDonald re-scheduled for 6/30 to come work on boiler
- The Aerzen blower errored out on 6/12 due to high temperature and is awaiting service in July.
- There were three after-hours alarm call out for the month as of June 23, 2026. Two power surges and multiple Hills Ranch alarms related to their recent maintenance work, and not an actual problem.
- The monthly CASGEM groundwater report was turned in on June 23, 2026, to the County.

Office:

- The District transferred \$125,000.00 on June 17, 2026, to District reserve LAIF Account. The current balance in this account is now \$1,134,331.00

Streetlights:

- Outfall:** No updates from Alpha diving on their schedule, but we reached out with a reminder email.

Recycled Water:

- MCCSD did not transfer any recycled water for the month. We anticipate resuming recycled water production and transfers at some point in 2027, after the system upgrades are completed.

Biosolids:

- Zero biosolids were transported in June of 2026.

Grants and Projects:

- Carollo Engineers have completed a draft site visit report and are now working on a schedule to begin the preliminary engineering report.

-Ghilotti Construction continues to make great progress on Phase II of the Recycled Water Upgrade and Expansion Project. Work at the WWTP is expected to begin in July. Plant shut down, de-watering, and cleaning is scheduled for the week of July 13, 2026. This temporary maintenance work should not last more than five days and presents the chance for increased odors. Staff will work to minimize this concern. There is a complaint form on the District website. Ghilotti was not on site the week of 6/22. Ghilotti's sub-contractor is still waiting on an approved boring plan for the work under Hwy 1, that will close the West side of Little Lake Road by Friendship Park. We again thank the community for your patience and understanding during this temporary inconvenience.

- MCCSD understands the MUSD potable water storage project is continuing on track.

Safety Meeting and Plant Safety Inspections:

The 30-minute monthly safety meeting was held on June 24, 2026. The topic was *Back Safety*.. No safety incidents were reported for the period.

June 2026 Superintendent's Report

Sanitary Sewer Collection System:

There are no Sanitary Sewer overflows to report for the period April 12, 2023- June 23, 2026. Hills Ranch had two new pump motors and sprockets installed to make their pumps run more efficiently. MCCSD received multiple alarm call outs during the work, but everything seems to be running smoothly now.