

November 2025 Superintendent's Report

Wastewater Treatment Plant:

- Operators performed routine repair and maintenance to the WWTP in November of 2025.
- There were zero plant alarm call outs for the month, as of 11/13/25.
- There was one after hours alarm call out for the Heeser Lift Station. It was due to a power outage; the generator started as designed and everything was found in working order upon arrival.
- Operators performed maintenance on the influent pumps and valves.
- RF MacDonald is still waiting to receive replacement filter valves.
- The bar screen problems seem to have been resolved. I am still supportive of purchasing a second unit for redundancy and heavy flows.
- The internal audit of our SSMP was completed and submitted.
- The CASGEM groundwater report was turned in 11/13/25 to the County.
- GHD submitted a proposal to update the District Asset Management Plan and provide a brief condition assessment that would include recommendations for priority projects.

Outfall:

- Nothing to report

Recycled Water:

- MCCSD did not transfer any recycled water for the month.

Biosolids:

- No biosolids were transported in the month of November.

Grants and Projects:

- FEMA has requested additional paperwork, apparently our 2023 file is not closed out. No current ETA on payments.
- The most recent SAFER group meetings were cancelled again this month. We learned that GHD Project Manager Holly Ziegler is leaving GHD and we are awaiting the assignment of a new project manager. We understand GHD is working on amendments to its work plan with the State which includes an update to the MCCSD Groundwater Model.
- Nothing to report on the Recycled Water Upgrade and Expansion Project.
- Nothing to report on MUSD, potable water storage tank project.

Safety Meeting and Plant Safety Inspection:

The 30-minute monthly safety meeting was held on November 7, 2025. The topic was *Confined Space Awareness*. Operators inspected safety equipment, no safety incidents were reported for the period. A member of the staff is attending a CPR and First Aid course on November 20, 2025.

Sanitary Sewer Collection System:

There are no Sanitary Sewer overflows to report for the period April 12, 2023- November 13, 2025.